








NOZZLE SCHEDULE							
ITEM	SIZE	RATING	TYPE	MATL.	PROJ. IN	PROJ. OUT	REMARKS
A	6"	N.P.T.	H.CPL.	C.S.	STD.	STD.	PRIMARY EMERGENCY VENT OPENING
B	6"	N.P.T.	H.CPL.	C.S.	STD.	STD.	SECONDARY EMERGENCY VENT OPENING
C	2"	N.P.T.	W.F.	C.S.	STD.	STD.	



- NOTES:
- MATERIAL: H.R. CARBON STEEL
 - DESIGN & OPERATING PRESSURE: ATMOSPHERIC.
 - DESIGN & OPERATING TEMPERATURE: AMBIENT.
 - TANK TO BE BUILT & LABELED PER U.L. SPEC. #142.
 - TANK TO BEAR MANUFACTURERS & U.L. LABELS ONLY.
 - TANK TO BE AIR TESTED WITH WATER & SOAP SUDS SOLUTION.
 - INTERIOR: REMOVE WELD SLAG (SHIP CLEAN & DRY).
 - EXTERIOR: GRAY PRIMER INCLUDED; SEE SALES ORDER FOR TOP COAT.
 - ALL FITTINGS TO BE PROTECTED FOR SHIPMENT.
 - CUSTOMER HAS THE RESPONSIBILITY TO VERIFY ALL DIMENSIONS.

APPROVAL FOR CONSTRUCTION SCHEDULE A - MASTER TERMS & CONDITION OF SALE*		SALES ORDER: -		WEIGHT (LBS): 1490	
☐ APPROVED AS DRAWN.				All units inches unless stated otherwise	
☐ APPROVED WITH NOTED CHANGES, CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND CONFIRMED ORDER ARE RECEIVED.		Phone: 870-735-4473			
SIGNATURE: _____		DESCRIPTION: 750 GALLON RECTANGULAR UL 142 DOUBLE WALL TANK			
DATE: _____		CUSTOMER: _____		P.O.# _____	
*All pages of this Schedule A are incorporated by reference and are a part of the additional terms of the Master Terms & Conditions of Sale. www.newberrytanks.com/masterterms.pdf		DATE: 3/7/2023		SCALE: _____	
		DWG.# FTDBS-0750		DRAWN BY: AJC	
				CHKD BY: _____	