

NO77LE COLEDITIE										
NOZZLE SCHEDULE										
ITEM	SIZE	RATING	TYPE	MATL	REMARKS	NOTES				
А	3"	N.P.T.	W.F.	C.S.	PRIMARY	EMERGENCY VENT OPENING				
В	3"	N.P.T.	H.CPL.	C.S.	SECONDARY	EMERGENCY VENT OPENING				
С	2"	N.P.T.	PIPE	C.S.	-	MONITORING PORT				
D	2"	N.P.T.	W.F.	C.S.	-	-				



## NOTES:

- A. Material: H.R. Carbon Steel.
- B. Design Pressure: Atmospheric.
- C. Design Temperature: Ambient.
- D. Built & Labeled per U.L. Spec. #142.
- E. Exterior: Gray primer included; see Sales Order for top coat.
- F. All Fittings to be protected for shipment.
- G. Customer to verify nozzle sizes, locations, and quantities.
- H. Saddles/skids may require shimming or grouting during installation.



•						
APPROVAL FOR CONSTRUCTION SCHEDULE A - MASTER TERMS &	SALES (	RDER:	WEIGHT (LBS): 775			
CONDITION OF SALE*	1	Newbei	rry Tanks	All units inches unless stated		
APPROVED AS DRAWN.	(- <u>(</u> )-	New Th	otherwise			
APPROVED WITH NOTED CHANGES,	Thew minking					
CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND	Phone: 870-735-4473					
CONFIRMED ORDER ARE RECEIVED.	DESCRIPTION:					
SIGNATURE:	300 GALLON 38" I.D. x 5'-0" O.A.L. DOUBLE WALL					
	BRACKET TANK					
DATE:	CUSTOMER:			IP.O.#		
*All pages of this Schedule A are incorporated by	OGG TOMETA.		-	_		
*All pages of this Schedule A are incorporated by reference and are a part of the additional terms of the Master Terms & Conditions of Sale.	DATE:	SCALE:	DWG.#	DRAWN BY: WR		
www.newberrytanks.com/masterterms.pdf	06/23/23		NB00300DWB03812G	SHEET 1 OF 1		
	•					

205 North Walker West Memphis, AR. 72301 870-735-4473 www.newberrytanks.com

Newberry Tanks & Equipment, LLC