
Notes:

- Tanks are constucted from 20-gauge G-90 grade galvanized steel or 304 stainless steel.
- Tops are constructed from 22-gauge G-90 grade galvanized steel or 304 stainless steel.
- All joints to be sealed with Sikaflex-1a, NSF-61 rated for potable water.
- Internal surfaces of the tank to be coated with Sherwin Williams, Macropoxy 646-PW NSF-61 rated.
- ° Optional 12" or 16" stainless steel screened filter basket.
- ° Standard bulkhead fitting thread 3/4", 1 1/4", or 2".



16299 FITZHUGH RD DRIPPING SPRINGS, TX (512) 565-0875 WWW.TEXASMETALTANKS.COM

SCALE: 1:35 PAGE: 1 DRAFTER: BRE AUGUST 2022

